


# Instruction For Use

**ATS-series** 

Automatic Transfer Switching Equipment





ATSE only be installed in the right place, be installed, debugged and maintained by special person. All operations (installation, connect must comply with this instruction. All ATSE on sale are marked and with complex construction. Anyone open it by himself without permisson does so at his own risk.

### 1.Overviews

# 1.1 The general

Suitable for AC 660 v and below, rated frequency 50 Hz, whether it is normal or not. As long as within the technical parameters of the switch, all can be guaranteed safely and reliably operat in the corresponding voltage grades of occasions.

### 1.2 Service conditions

- 1.2.1 ambient air temperature
- A) the highest temperature  $\leq +60^{\circ}$ C:
- B) the lowest temperature ≥ 20°C
- C) the highest average temperature ≤ + 60°C
- D) the ambient air temperature is higher than  $+60^{\circ}$ C or below-20°C the user should negotiate with the manufacturer.
- E) environmental temperature  $> 60 \,^{\circ}\text{C} \leq 80 \,^{\circ}\text{C}$  should reduce capacity selection(off about 20%);
- 1.2.2 atmospheric temperature

When the highest temperature + 60  $^{\circ}$ C relative humidity  $\leq$  50%. Moist air on the sea will influence capability when the max monthly RH is 90%.

1.2.3 installation elevation

The installation elevation≤ 2000 m. When used in higher altitudes, the user should check with the manufacturer as decrease of electric strength and cooling action.

1.2.4 pollution levels

Class of pollution: class 3.

1.2.5 installation category

Installation category as class IV.

1.2.6 installation tilt

ATSE is a rack fixed installation, installation tilt  $\leq \pm 22.5$ .

1.2.7 use categories: AC - 33 ib

### 1.3 Product features

- 1.3. 1 installation performance is good
- 1.3. 2 with double row composite contact, horizontal pull-out mechanism micromotor energy storage and microelectronic control technology, the basically zero arcing (no arc clute)
- 1.3. 3 use reliable mechanical interlock and electric interlock, ensure higher Security
- 1.3. 4 using a zero technology, an emergency can be forced to zero at the same time to cut off the two power supplies
- 1.3. 5 has obvious on/off position indicator, padlock, and other functions. Insulate the power and the load reliably. With high reliability and more than 10000 times using life.
- 1.3. 6 good electromagnetic compatibility, strong anti-interference ability, no interference
- 1.3. 7 high automaticity
- 1.3. 8 switch has multiple input/output interface, easy to implement remote PLC control and system automation. Switch can work without any other controller.
- 1.3. 9 beautiful shape, small volume, light weight. The logic control board can control operation of the motor(inside the switch)using differentlogic to make sure the switch on it's position.

### 1.3 Features


ATSE series as the main, dual power automatic transfer switch is mainly used in the first class load and second class load (which need back-up power) confirmed by the nati- onal regulations, suitable for highrise buildings, post and telecommunications, coal and shipping, industrial assembly line, health care, military facilities, etc. The main standby power can be grid, generator, battery, etc. The main standby power can be customized by users. Transfer time of the main switch body is not more than 1s. Users can make special delay when necessary. The main power takes priority over the main standby power when supply electricity together.

# 2.1 The main technical parameters

### Meet IEC947-6-1 / GB 14048, 11

Rated thermal current		80A	100A	125A	160A	250A	400A	630A	800A	1000A	1250A	1600A	2000A	2500A	3200A
Rated insulation voltage		750V				1000V									
The rated impulse withstand voltage		8KV				12KV									
Rated operational voltage		AC440V													
The rated working current	AC-33IB	80	100	125	160	250	400	630	800	1000	1250	1600	2000	2500	3200
Rated making ability		10Ie													
The rated breaking capacity		81e													
Rated conditional short-circuit current		100KA				70	70KA 100KA 100KA		80KA						
Rated short-time withstand current		7KA 9KA		13KA 5		50	)KA		55KA						
Conversion time		≤0.45S ≤0.45S		45S	≤0.6S		≤1.2S				≤1.4S				
		≤3S(YC type) ≤3.5S(YC ty		YC type)			≥1.25								
The supply voltage Standard: AC 220 v, customizable AC110V, AC380V, DC12V DC24V															

### 2.2 switch structure




### 2.3 Terminal function


Terminal no.	Node number	Features	Explanation		
	101、106	Power zero line, FireWire Out	Active output, 1A AC220V		
No. 1 terminal	102、103	I work way power zero line, FireWire input	AC 220V		
	104、105	II work way power zero line, FireWire input	AC 220V		
	201、206	Disconnect passive control closed for the active control	See SYK1 type Schematic		
	202	External passive control signal input common			
No. 2 terminal	203	I closed the road and after 202 Closing			
	204	0 closed the road and after 202 Closing	I / II line open		
	205	II closed the road and after 202 Closing			
	301、306	Unused, even inside has been	400A above assembly		
	302	Passive position feedback signal output common			
No. 3 terminal	303	I closed the road after closing and 302	The basic model is an active output,		
	304	0 closed the road after closing and 302	other Model passive output,		
	305	II closed the road after closing and 302			
	401、406	Unused, even inside has been	400A above assembly		
No. 4 terminal	402、403	I closed the road after closing	Passive 1A AC220V		
	404、405	II closed the road after closing	Passive 1A AC220V		
No. 5 terminal	501~506	Custom signal output terminal	400A above assembly Passive 1A AC220V		

- 1, Electric lock: control the power of control circuit inside the switch. When the electric lock turned on, the switch can be remotely operated, otherwise the switch will be hand operation.
- 2, Operation handle: electric lock must be closed when using operation handle.
- 3, Mechanical padlock: Before you overhaul, you must turn off the electric lock, use the operating handle to force the switch to "0" position, pull the mechanical padlock and lock it.
- 4, Position indicator: indicate working status of the switch(I,0,II).
- 5, The control voltage: AC220V.
- 6, The switch body: part in the front is line I, connect with the normal power. Part at the back is line II, connect with the standby power.


## 2.4 correct installation schematic diagram



## 2.5 Installation size



# 2.6 all types of wiring



2, the use of intelligent controller, use the 3rd terminal access controller as a feedback signal port, use the 4th port terminal as an external indicator


1, the drawing applies only to standard ATS switches at the access switch bronze voltage:

Explanation:

AC380/220V (three-phase four-wire), in the case of 50 / 60Hz use,

Fu1/FU2 is 2A fuse 101 to 106, 201-206, 301-306 as SYK switch terminal 630A switch terminal can be used for more than 401-406, 501-506 Note: This wiring diagram applies and 2, 3, 4, 5

### 1, the automatic wiring (basic)



220V input load side switch status indicator

- Imain power indicator
- II standby power indicator

### 2, automatic wiring




Automatic Wiring

# 3、Automatic + forced zero protection(fire fighting, dual power supply are disconnected)




Forced zero contacts Passive input

### 4、Remote control (manual only) Wiring



Sb1, SB0, SB2 respectively common power, forced to zero, spare Power-control buttons (passive contact)

# 5、 Automatic + Manual (remote control) Wiring




SA is the switch choose automatic or manual mode. SB1 is the manually input button for main power. (passive contact).

SB2 is the manually input button for standby power (passive contact).

### 6、the starter-generator signal wiring

Has brought a generator interface (301-306 words have UGE1), Wiring diagram is as follows




UGE1 passive contact connected generator Interface

Description: UGE1 internal AC220V relay to switch 301 306 starter generator Interface

NOTE: The above is about "the 2nd switch terminal" control wiring, the user can choose one, just to copper automatic power introduced, do not need another then the second line, 302-305 switching state instructions, such as users need to connect their own. Terminal method: only one set of six terminals

### 7. Generator connection mode



Note: 101-106 for switching power supply input and output terminals

201-206 for switch control terminals

301-306 for the switch status indication terminal

1 Qf primarily circuit (mains) protection switch alarm contacts

1 Kt for power on delay (0-180s), 2 kt for power off delay (0-180s)

## 3.1 switch wiring instructions (see 2.2 switch structure)

- 3.1. 1 switch from left to right, I copper busbar connect with A, B, C, N of Commonly used power(in the front) and II connect with standby power(at the back).
- 3.1. 2 control power is taken from C of commonly used power and N of stand by Power
- 3.1. 3 .control power AC220V of line I connect to terminal 102~103,control power AC220V of line II connect to terminal 104~105. 102 is fire wire for commonly used power and 104 is fire wire for standby power.
- 3.1. 4 terminal 101,106, just as a light control power, of which 106 is fire wire. Note that 101, 106 can not connected to any other lines!.
- 3.1. 5 When the top(bottom) of line I inset wire, A,B,C,N at the bottom (top) use connection of copper busbar to output it. And line II use wires.

# 4.1 common problems and solutions.

	Problems	Reasons	Solutions		
1		Whether the button pressed on the automatic position	Choose the automatic position		
	Power On, ATS does not work	Whether working power of the switch is connected	Access to the control power correctly		
		3. 2, tif connection mode of terminal 2 is correct	Access to signal control line correctly		
		4. The fuse is damaged	Replacing the fuse		
2	Power on, circuit board burned	check line 101-106 to make sure it is normal	Replace the circuit board		

### Schedule

# Packing List

ATS / 1 station, machinery operating handle / 1 set, cable fixing bolts / 1 set, Security guard / 1 set (optional)

Manual/1, single factory inspection/1, certification/1

### Mount the cabinet reference Dimensions

Current (A)	The maximum length switch	The maximum width switch	The maximum height switch	Recommended cabinet	
	Lmax(mm)	Wmax(mm)	Hmax(mm)	(L * W * H mm)	
2000-3200	635	505	470	800*800*2200	
1600	635	321	407	800*600*2200	
800-1250	635	321	350	800*600*1800	
400-630	435	262	270	600*500*1500	
250	360	195	170		
125-160	303	195	142	500*400*1200	
20-100	245	133	106		

## Explanation:

- 1, the maximum length Lmax switch mounting bracket to the left to the right and left vertical surface mounting distance holder the right facade.
- 2, the maximum width Wmax switch after mounting bracket to the front façade manual emergency handle the interface facade distance.
- 3, switch on the maximum height Hmax of copper facade from the top to the bottom of the facade at the bronze medal.
- 4, the height of the cabinet space required, please consider the actual situation isochronous operation and connecting cables.



As time goes on constantly, constantly updated technology, subject to change without further notice, product image if there is a difference in kind, please prevail in kind, The Company reserves the right of final interpretation and modification of information!



Cherish resources, treat the environment

# TRACING SUYANG QUALITY ROCK SOLID

### YANGZHOU SUYANG ELECTRIC CO.,LTD

- Yongxun Road 1 , Dayi Industrial Zone, Yongxun Koau T, Dayi Industria. 2017.
  Dayi Town, Yangzhou, Jiangsu, China
- +86 0514-82888885
- +86 400-888-5848
- @ http://www.yzsuyang.cn